



Karnataka Fire & Emergency Services Department
Office Of the District Fire Officer
North Fire Station
Bangalore-560018.



No.09/FSR/DFO/NFS/2024.

Date:12/02/2024.

ANNEXURE-A

"B1 & B2 - Schools up to senior secondary level and other institutions"

To,
The Authorized Signatory,
M/s. Sree Sharadamba vidyaniketan School,
No.59/8, Javaregowda nagara, Hosakerehalli road,
(Near Ideal Homes), R.R Nagara Bengaluru-560098.

Sub: Issue of "Fire safety Recommendation" with respect of fire prevention, fire fighting & evacuation measures required at M/s. Sree Sharadamba vidyaniketan School, No.59/8, Javaregowda nagara, Hosakerehalli road, (Near Ideal Homes), R.R Nagara Bengaluru-560098.

Ref: 1) Your Request Letter- Dated -09-02-2024.

><<>*@*<><<

With reference to the subject above cited, the premises to "M/s. Sree Sharadamba vidyaniketan School, No.59/8, Javaregowda nagara, Hosakerehalli road, (Near Ideal Homes), R.R Nagara Bengaluru-560098". was inspected by me on 09-02-2024 with respect to Fire prevention, Fire fighting and Evacuation measures to be Recommended in the above premises and has submitted the details as under.

Details of the building / premises :-

01	Name and Address of the Applicant.	: The Authorized Signatory, M/s. Sree Sharadamba vidyaniketan School, No.59/8, Javaregowda nagara, Hosakerehalli road, (Near Ideal Homes), R.R Nagara Bengaluru-560098.
02	Name and Address of the premises.	: M/s. Sree Sharadamba vidyaniketan School, No.59/8, Javaregowda nagara, Hosakerehalli road, (Near Ideal Homes), R.R Nagara Bengaluru-560098.
03	Name and address of the Building owner	: Sri. Gopal K. Nagendra NO-339, 1 st D Cross, 4 th main, 3 rd stage, 6 th

SREE SHARADAMBA VIDYA NIKETAN



Principal
SREE SHARADAMBA VIDYA NIKETAN
No. 59/8, Javaregowda Nagar
(Near Ideal Homes)

Chairmen

04	Number of buildings	:	Block, 2 nd Phase, BSK 3 rd Stage, Bengaluru-560085.
05	Number of floors	:	One building
06	Floor-wise details of occupancy:-		
	Ground floor	:	05 Class rooms, 01 Office room, 01 Principal room, 01 Staff room, 02 Wash rooms.
	1 st floor	:	06 class rooms, 01 Library room, 02 wash rooms, 01 Sports room, 01 Lab, 01 Store room.
	2 nd floor	:	04 Class rooms, 02 wash rooms, 01 Lab, 01 Auditorium, 01 Chairman room, 01 Store room.
07	Height of the building	:	09.50 Mtrs.
08	Site area	:	8,498.40 Sq. Mtrs.
09.	Built-up area of each floor:-		
	Ground floor	:	620.00 Sq.Mtrs
	1 st floor	:	620.00 Sq.Mtrs
	2 nd floor	:	620.00 Sq.Mtrs
10.	Total built-up area	:	1,860.00 Sq.Mtrs
11.	Surrounding properties:-		
	South (Front)	:	06.00 mtrs wide road
	North (Rear)	:	Private property
	East (Side)	:	Private property
	West (Side)	:	Private property
12.	Set-back area available around the building :-		
	South (Front)	:	08 mtrs
	North (Rear)	:	07 mtrs
	East (Side)	:	150 mtrs
	West (Side)	:	08 mtrs

B. On inspection of this Educational premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)

For SREE SHARADAMBA VIDYA NIKETAN

Chairman



Principal
SREE SHARADAMBA VIDYA
No. 59/8, Javaregowda
Near West Home To
North Bengaluru

01. Accessibility to the premises	The premise is abutting 06.00 mtrs wide road located on Southern side of the Road is hardened to Carry weight of 15,000 kg's. One entrances/exits have been provided. width of 04.00 Mtrs, the building.		The Requirement is Complied With.																				
02. No. of entrances	Nor provided		The Requirement is Complied With.																				
03. Diesel Generators	Nor provided		One adequate Capacity of Diesel Generator Should be provided and It connected to supply alternative power for staircase lighting, corridor lighting and etc., in the event of failure of electricity supply in the building.																				
04. No. of staircases available	<table border="1"> <tr> <td>Nos. of staircases</td> <td>:</td> <td>01 no</td> </tr> <tr> <td>Width of staircases</td> <td>:</td> <td>01.60 Mtr's</td> </tr> <tr> <td>Width of treads</td> <td>:</td> <td>30 Cm's</td> </tr> <tr> <td>Height of risers</td> <td>:</td> <td>15 Cm's</td> </tr> <tr> <td>Nos. of riser per flight</td> <td>:</td> <td>11 No's</td> </tr> <tr> <td>Height of handrails</td> <td>:</td> <td>01.00 mtrs.</td> </tr> <tr> <td>Head room clearance</td> <td>:</td> <td>2.50 mtrs</td> </tr> </table>	Nos. of staircases	:	01 no	Width of staircases	:	01.60 Mtr's	Width of treads	:	30 Cm's	Height of risers	:	15 Cm's	Nos. of riser per flight	:	11 No's	Height of handrails	:	01.00 mtrs.	Head room clearance	:	2.50 mtrs	The Requirement is Complied With.
Nos. of staircases	:	01 no																					
Width of staircases	:	01.60 Mtr's																					
Width of treads	:	30 Cm's																					
Height of risers	:	15 Cm's																					
Nos. of riser per flight	:	11 No's																					
Height of handrails	:	01.00 mtrs.																					
Head room clearance	:	2.50 mtrs																					
05. No. lifts and capacity.	Not Provided		Not Required																				
06. Fire extinguisher	03 no's CO ₂ type fire extinguisher of 4.5 kg's capacity, 01 no CO ₂ type fire extinguisher of 02 kg's capacity, & ABC type of fire extinguisher of 06 kg's capacity has been provided.	<p>A. As Proposed 01 No CO₂ type fire extinguisher of 4.5 kg's capacity Shall be provided near each electrical panel board & electrical room.</p> <p>B. As Proposed One ABC</p>																					



Road, Bangalore 560029
regarding the
maintenance of the fire
prevention and fire
fighting measures
suggested above.

15. Fire precaution measures :-
- Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.
 - Accumulation of combustible waste in and around the premises should be avoided.
 - The exit ways shall be always kept clear without any obstruction.
 - Liquefied petroleum gas (LPG) should be not stored in the building.
 - The doors shall not be kept locked/latched during working hours and shall be free from obstruction.
 - During the class hours the class room doors shall not be locked from inside to outside.
 - As per Hon'ble Supreme Court order all teacher and staff shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety day on April 14th of every year by conducting fire safety drills with co-ordinate with Fire Service Department.

From the above details it is clear that the applicant shall adopt all necessary fire prevention and fire fighting measures in the building. In Issue "**Fire Safety Recommendation**" for Low Rise Educational Building at "**M/s. Sree Sharadamba vidyaniketan School, No.59/8, Javaregowda nagara, Hosakerehalli road, (Near Ideal Homes), R.R Nagara Bengaluru-560098**". This Fire Safety Renewal Recommendation report is valid for a period of only one year from the date of issue and is Renewable.

✦ All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.4 of Fire and Life safety will have to be complied with mandatorily.

Yours faithfully

K.H. Prasad 12/02/24
District Fire Officer
Karnataka State Fire & Emergency Services
North Fire Station, Mysore Road,
Bangalore - 560 018.

For SREE SHARADAMBA VIDYA NIKETAN

Chairman

Principal
SREE SHARADAMBA VIDYA NIKETAN
No. 59/8, Javaregowda Nagar,
Hosakerehalli, Bengaluru - 560098